



**BALTIMORE AIRCOIL AUSTRALIA**

# CERTIFICATE OF COMPLIANCE

Baltimore Aircoil Evaporative Condenser / Cooler Coils are designed and approved for use throughout Australia and New Zealand to the AS 1210 Class 3, Hazard Level B Standard

Design Pressure	2,200 kPaG	Test Pressure	2,750 kPaG	Approval Number	5149 P 9G
-----------------	------------	---------------	------------	-----------------	-----------

The Certificate of Plant Design Registration is issued by SafeWork NSW and is a re-issue of a certificate originally issued under WorkCover NSW

Purchase, installation and operation of pressure equipment requires Australian Government Design Registration. Non-compliant plant is a risk to life and can be prohibited from operating until it is demonstrated to be safe. Design registration is the responsibility of the manufacturer or importer of the equipment and failure to prove registration of installed equipment may lead to compliance action, financial penalties and legal action in the case of an incident.

*The Baltimore Aircoil design registration nameplate affixed to your coil is your peace-of-mind that your solution is backed by the experts in the business*



On behalf of Baltimore Aircoil Pty Ltd  
ABN 77 008 497 443

